ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
340491870263003	Green Bay	Early Childhood Center	1/12/18	6:00 AM	JO	GB1A	Main Office A	DF - Drinking Fountain	1/11/2018	7:15 PM	First Draw	250	ARRO Laboratory	EPA 200.5	5.37	2.00	
340491870263003	Green Bay	Early Childhood Center	1/12/18	6:00 AM	JO	GB1B	Main Office A	DF - Drinking Fountain	1/11/2018	7:15 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
340491870263003	Green Bay	Early Childhood Center	1/12/18	6:01 AM	JO	GB2A	Main Office B	DF - Drinking Fountain	1/11/2018	7:16 PM	First Draw	250	ARRO Laboratory	EPA 200.5	5.11	2.00	
340491870263003	Green Bay	Early Childhood Center	1/12/18	6:01 AM	JO	GB2B	Main Office B	DF - Drinking Fountain	1/11/2018	7:16 PM	Flush	250	ARRO Laboratory	EPA 200.5	2.00	2.00	
340491870263003	Green Bay	Early Childhood Center	1/12/18	6:03 AM	JO	GB3A	A Wing E hall North Side	DF - Drinking Fountain	1/11/2018	7:17 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
340491870263003	Green Bay	Early Childhood Center	1/12/18	6:03 AM	JO	GB3B	A Wing E hall North Side	DF - Drinking Fountain	1/11/2018	7:17 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
340491870263003	Green Bay	Early Childhood Center	1/12/18	6:04 AM	JO	GB4A	A Wing E Hall South Side	DF - Drinking Fountain	1/11/2018	7:18 PM	First Draw	250	ARRO Laboratory	EPA 200.5	3.60	2.00	
340491870263003	Green Bay	Early Childhood Center	1/12/18	6:04 AM	JO	GB4B	A Wing E Hall South Side	DF - Drinking Fountain	1/11/2018	7:18 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	